

CLIENT AND LOCATION DETAILS

Philip Harvey
16 Church Street

Twenty 20 Events
16 Church Street

Hoo
Kent ME3 9AH

Hoo
Kent ME3 9AH

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
0001	Large LED Letter W	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0002	Large LED Letter Z	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0003	Large LED Letter Y	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass
0004	Large LED Letter X	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0005	Large LED Letter V	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0006	Large LED Letter V	06/05/2026	1	230	Pass	0.05	19.99	0.00	0.10					Pass
0007	Large LED Letter U	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0008	Large LED Letter U	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0009	Large LED Letter T	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0010	Large LED Letter T	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0011	Large LED Letter S	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.10					Pass
0012	Large LED Letter S	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0013	Large LED Letter R	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0014	Large LED Letter R	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0015	Large LED Letter Q	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass
0016	Large LED Letter P	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0017	Large LED Letter O	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.10					Pass
0018	Large LED Letter O	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0019	Large LED Letter N	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0020	Large LED Letter N	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0021	Large LED Heart	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0022	Large LED Heart	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0023	Large LED Letter M	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.10					Pass
0024	Large LED Letter M	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0025	Large LED Letter L	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0026	Large LED Letter L	06/05/2026	1	230	Pass	0.11	19.99	0.00	0.10					Pass
0027	Large LED Letter K	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0028	Large LED Letter K	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass
0029	Large LED Letter J	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0030	Large LED Letter J	06/05/2026	1	230	Pass	0.04	19.99	0.00	0.10					Pass
0031	Large LED Letter I	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0032	Large LED Letter H	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0034	Large LED Letter G	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0035	Large LED Letter G	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0036	Large LED Letter F	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0037	Large LED Letter F	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.10					Pass
0038	Large LED Letter E	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0039	Large LED Letter D	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass

CONTRACTOR DETAILS

DJ Sounds PAT Testing
73 Highfield Road
Dartford
Kent
DA1 2JU

07804 209078

Tester Name David Hare
Qualifications City & Guilds 2377-12
Position P.A.T. Tester

Signature



CLIENT AND LOCATION DETAILS

Philip Harvey
16 Church Street

Twenty 20 Events
16 Church Street

Hoo
Kent ME3 9AH

Hoo
Kent ME3 9AH

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD SI	Status
0040	Large LED Letter D	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0041	Large LED Letter C	06/05/2026	1	230	Pass	0.05	19.99	0.00	0.10					Pass
0042	Large LED Letter C	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0043	Large LED Letter B	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass
0044	Large LED Letter A	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0045	Large LED Letter A	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0046	Large LED Letter H	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0047	Large LED Letter &	06/05/2026	1	230	Pass	0.11	19.99	0.00	0.10					Pass
0048	Large LED Letter P	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0049	Large LED Letter V	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0050	Large LED Letter E	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0051	Large LED Letter O	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0052	Large LED Letter L	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0053	Large LED Letter &	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0054	Large LED Number 1	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0055	Large LED Number 2	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0056	Large LED Number 3	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0057	Large LED Number 4	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.10					Pass
0058	Large LED Number 5	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0059	Large LED Number 6	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.10					Pass
0060	Large LED Number 7	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0061	Large LED Number 8	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass
0062	Large LED Number 9	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.10					Pass
0063	6 Way Surge Protector	06/05/2026	1	230	Pass	0.16	19.99	0.00	0.00					Pass
0064	10 Way Surge Protector	06/05/2026	1	230	Pass	0.14	19.99	0.00	0.00					Pass
0065	6 Way Surge Protector	06/05/2026	1	230	Pass	0.09	19.99	0.00	0.00					Pass
0066	4 Way Surge Protector	06/05/2026	1	230	Pass	0.15	19.99	0.00	0.00					Pass
0067	Iec Lead	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.00					Pass
0068	Iec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0069	Iec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0070	Iec Lead	06/05/2026	1	230	Pass	0.05	19.99	0.00	0.00					Pass
0071	Iec Lead	06/05/2026	1	230	Pass	0.05	19.99	0.00	0.00					Pass
0072	Iec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0073	Iec Lead	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.00					Pass
0074	Iec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0075	Iec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0076	Iec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0077	Iec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass

CONTRACTOR DETAILS

DJ Sounds PAT Testing
73 Highfield Road
Dartford
Kent
DA1 2JU

07804 209078

Tester Name David Hare
Qualifications City & Guilds 2377-12
Position P.A.T. Tester

Signature



CLIENT AND LOCATION DETAILS

Philip Harvey
16 Church Street

Twenty 20 Events
16 Church Street

Hoo
Kent ME3 9AH

Hoo
Kent ME3 9AH

TEST RESULTS

Asset ID	Description	Test Date	Class	Volts	Visual	Cont	Ins.	Oper.	Leak.	Extn.	Flash	RCD I	RCD 5I	Status
0078	lec Lead	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.00					Pass
0079	lec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0080	lec Lead	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.00					Pass
0081	lec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0082	lec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0083	lec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0084	lec Lead	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.00					Pass
0085	lec Lead	06/05/2026	1	230	Pass	0.05	19.99	0.00	0.00					Pass
0086	Class 2 Power Lead	06/05/2026	2	230	Pass		19.99	0.00	0.00					Pass
0087	lec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0088	lec Lead	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.00					Pass
0089	lec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0090	Canon CA-PS700	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0091	6 Way Surge Protector	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.00					Pass
0092	4 Way Extension Lead	06/05/2026	1	230	Pass	0.32	19.99	0.00	0.00					Pass
0093	Speakon Power Lead	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.00					Pass
0094	lec Lead	06/05/2026	1	230	Pass	0.06	19.99	0.00	0.00					Pass
0095	Switching Power Supply	06/05/2026	2	230	Pass		19.99	0.00	0.17					Pass
0096	AC / DC Adapter	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0097	lec Lead	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.00					Pass
0098	Dance Floor Power Supply	06/05/2026	1	230	Pass	0.11	19.99	0.00	0.55					Pass
0099	lec Lead	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.00					Pass
0100	DND Model DP-DS620	06/05/2026	1	230	Pass	0.08	19.99	0.00	0.58					Pass
0101	Gold Source ST-2000	06/05/2026	1	230	Pass	0.13	19.99	0.00	0.10					Pass
0102	GVE AC/DC Adapter	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0103	GVE AC/DC Adapter	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0104	4 Way Extension Lead	06/05/2026	1	230	Pass	0.23	19.99	0.00	0.00					Pass
0105	4 Way Extension Lead	06/05/2026	1	230	Pass	0.33	19.99	0.00	0.00					Pass
0106	lec Lead	06/05/2026	1	230	Pass	0.11	19.99	0.00	0.00					Pass
0107	D-Lite RX One	06/05/2026	2	230	Pass		19.99	0.00	0.10					Pass
0108	lec Lead	06/05/2026	1	230	Pass	0.10	19.99	0.00	0.00					Pass
0109	Mitsubishi CP-D80DW	06/05/2026	1	230	Pass	0.07	19.99	0.00	0.10					Pass

CONTRACTOR DETAILS

DJ Sounds PAT Testing
73 Highfield Road
Dartford
Kent
DA1 2JU

07804 209078

Tester Name David Hare
Qualifications City & Guilds 2377-12
Position P.A.T. Tester

Signature

